

HKB1011

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	39.95	31.69	26.74	23.44	21.07	19.37
Approach (4)°C	53.30	41.74	35.00	30.49	27.23	24.78
Approach (5)°C	67.23	52.45	43.75	37.94	33.75	30.67
Approach (6)°C	82.36	63.92	53.03	45.85	40.76	36.87
Approach (7)°C	98.12	75.98	62.81	54.19	48.08	43.52

Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	42.14	33.44	28.26	24.82	22.36	20.58
Approach (4)°C	56.20	44.15	37.05	32.32	28.97	26.38
Approach (5)°C	71.02	55.49	58.30	40.18	35.85	32.59
Approach (6)°C	86.65	67.45	56.07	48.48	43.12	39.15
Approach (7)°C	103.25	80.22	66.29	57.27	50.76	46.07

Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	44.64	35.44	29.91	26.25	23.61	21.83
Approach (4)°C	59.33	46.65	39.10	34.19	30.71	27.99
Approach (5)°C	74.91	58.57	48.97	42.36	37.94	34.55
Approach (6)°C	91.42	71.16	59.28	51.11	45.71	41.47
Approach (7)°C	108.97	84.64	70.13	60.62	53.84	48.75

Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	47.14	37.54	31.83	27.99	25.27	23.17
Approach (4)°C	62.54	49.42	41.43	36.29	32.54	29.69
Approach (5)°C	79.01	61.92	51.65	44.95	40.22	36.65
Approach (6)°C	96.42	75.26	62.59	54.28	48.39	43.97
Approach (7)°C	114.81	89.32	74.15	64.15	57.01	51.65

Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	49.77	39.77	33.70	29.64	26.83	24.64
Approach (4)°C	66.20	52.27	43.88	38.44	34.51	31.56
Approach (5)°C	83.52	65.49	54.77	47.68	42.72	38.93
Approach (6)°C	101.73	79.50	66.34	57.50	51.34	46.56
Approach (7)°C	121.06	94.28	78.39	67.90	60.31	54.86

Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	52.59	42.10	35.76	31.52	28.44	26.20
Approach (4)°C	69.91	55.31	46.56	40.76	36.60	33.61
Approach (5)°C	88.07	69.33	58.03	50.49	45.22	41.29
Approach (6)°C	107.18	84.01	70.00	60.89	54.33	49.46
Approach (7)°C	127.72	99.55	82.90	71.87	63.92	58.17

HKB1011

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	55.89	44.64	37.85	33.44	30.22	27.81
Approach (4)°C	73.88	58.57	49.37	43.08	38.88	35.62
Approach (5)°C	93.16	73.25	61.38	53.57	47.99	43.84
Approach (6)°C	113.25	88.88	74.19	64.50	57.50	52.50
Approach (7)°C	134.77	104.95	89.10	76.11	67.72	61.65
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	59.06	47.32	40.27	35.53	32.19	29.60
Approach (4)°C	78.21	61.96	52.36	45.89	41.34	37.81
Approach (5)°C	98.34	77.50	65.09	56.78	50.93	46.60
Approach (6)°C	119.68	93.97	78.57	68.34	61.11	55.71
Approach (7)°C	142.18	111.24	92.81	80.66	71.87	65.35
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	62.54	50.18	42.68	37.77	34.19	31.52
Approach (4)°C	82.76	65.71	55.49	48.70	43.93	40.22
Approach (5)°C	103.92	82.05	69.06	60.26	54.10	49.51
Approach (6)°C	126.38	99.37	83.21	72.50	64.86	59.19
Approach (7)°C	150.08	117.72	98.25	85.40	76.20	69.42
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	66.29	53.26	45.40	40.13	36.38	33.52
Approach (4)°C	87.58	69.64	58.92	51.78	46.69	42.81
Approach (5)°C	109.95	86.96	73.12	63.97	57.45	52.54
Approach (6)°C	133.61	105.17	88.12	76.87	68.88	62.85
Approach (7)°C	158.47	124.37	104.06	90.53	80.89	73.66
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	70.35	56.56	48.21	42.68	38.70	35.71
Approach (4)°C	92.67	73.79	62.50	54.95	49.60	45.58
Approach (5)°C	116.33	92.09	77.54	67.90	61.07	55.89
Approach (6)°C	141.15	111.33	93.43	81.56	73.12	66.78
Approach (7)°C	167.40	131.55	110.22	95.98	85.84	78.30
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	74.50	60.04	51.25	45.40	41.20	38.03
Approach (4)°C	98.12	78.30	66.38	58.43	52.81	48.48
Approach (5)°C	123.03	97.58	82.27	72.09	64.91	59.46
Approach (6)°C	149.19	117.89	99.01	86.56	77.63	70.98
Approach (7)°C	176.82	139.28	116.73	101.73	91.15	83.16

HKB1516

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	61.07	48.73	41.34	36.46	32.82	30.26
Approach (4)°C	80.87	63.89	53.87	47.17	42.41	38.71
Approach (5)°C	101.54	79.93	66.90	58.32	52.18	47.54
Approach (6)°C	123.53	96.78	80.62	70.09	62.45	56.81
Approach (7)°C	146.51	114.32	95.21	82.50	73.41	66.52
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	64.64	51.49	43.72	38.52	34.89	32.07
Approach (4)°C	85.13	67.53	56.88	49.86	44.72	40.97
Approach (5)°C	107.11	84.25	70.78	61.51	55.12	50.30
Approach (6)°C	129.79	101.98	85.25	74.10	66.21	60.32
Approach (7)°C	154.34	120.52	100.47	87.13	77.67	70.72
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	68.15	54.56	46.42	40.90	36.96	34.08
Approach (4)°C	89.83	71.41	60.13	52.74	47.48	43.41
Approach (5)°C	112.75	88.95	74.60	65.15	58.44	53.37
Approach (6)°C	137.06	107.36	89.83	78.17	70.09	63.70
Approach (7)°C	162.30	127.16	106.17	92.02	82.06	74.73
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	71.85	57.69	49.11	43.35	39.15	36.08
Approach (4)°C	95.02	75.36	63.64	55.81	50.30	46.10
Approach (5)°C	118.89	93.77	78.93	69.03	61.89	56.50
Approach (6)°C	144.20	113.50	95.09	82.68	73.98	67.53
Approach (7)°C	170.94	134.17	112.00	97.28	86.94	79.11
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	75.98	61.14	51.99	45.92	41.72	38.40
Approach (4)°C	100.16	79.43	67.34	59.13	53.37	48.92
Approach (5)°C	125.47	99.22	83.56	72.98	65.52	59.95
Approach (6)°C	152.03	119.64	100.41	87.63	78.43	71.53
Approach (7)°C	180.03	141.44	118.08	103.04	91.96	83.75
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	80.30	64.64	55.00	48.73	44.16	40.72
Approach (4)°C	105.74	84.06	71.22	62.58	56.50	51.87
Approach (5)°C	132.23	104.61	88.39	77.36	69.53	63.58
Approach (6)°C	160.30	126.34	105.99	92.64	83.06	75.79
Approach (7)°C	189.74	149.21	125.34	108.87	97.22	88.89

HKB1516

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	84.94	68.34	58.38	51.68	46.98	43.28
Approach (4)°C	111.56	88.95	75.67	66.40	59.95	55.12
Approach (5)°C	139.44	110.62	93.52	82.00	73.79	67.53
Approach (6)°C	168.94	133.61	112.19	97.97	88.07	80.37
Approach (7)°C	199.95	157.48	132.36	115.13	103.04	94.02
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	89.89	72.54	61.95	54.81	49.92	46.04
Approach (4)°C	117.95	94.27	80.12	70.34	63.64	58.51
Approach (5)°C	147.45	117.07	98.91	86.69	78.05	71.47
Approach (6)°C	178.65	141.13	118.89	103.79	93.33	85.32
Approach (7)°C	210.78	166.25	139.62	121.90	109.24	99.72
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	95.09	76.80	65.71	58.26	52.93	48.92
Approach (4)°C	124.65	99.60	84.75	74.73	67.53	62.14
Approach (5)°C	155.47	123.84	104.67	91.96	82.81	75.92
Approach (6)°C	188.11	149.02	125.59	110.00	98.78	90.39
Approach (7)°C	222.31	175.58	147.58	129.04	115.76	105.67
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	100.73	81.31	69.78	61.89	56.31	51.99
Approach (4)°C	131.61	105.67	89.83	79.30	71.72	66.02
Approach (5)°C	164.12	131.04	110.87	97.41	87.95	80.62
Approach (6)°C	198.76	157.66	132.86	116.64	104.80	95.96
Approach (7)°C	234.46	185.60	156.22	136.68	122.59	112.06
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	106.55	86.26	73.98	65.83	59.88	55.31
Approach (4)°C	139.19	111.94	95.28	84.19	76.17	70.28
Approach (5)°C	173.51	138.50	117.51	103.29	93.27	85.63
Approach (6)°C	209.66	166.62	140.75	123.59	111.19	101.92
Approach (7)°C	247.30	196.00	165.18	144.51	129.98	118.95
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	112.69	91.45	78.55	69.91	63.70	59.01
Approach (4)°C	147.27	118.39	101.10	89.39	80.99	74.67
Approach (5)°C	183.35	146.64	124.40	109.56	99.03	91.02
Approach (6)°C	221.18	176.27	149.08	130.85	118.08	108.18
Approach (7)°C	261.08	207.21	174.83	153.22	137.81	126.22

HKB1521

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	82.25	66.04	56.21	49.75	45.08	41.45
Approach (4)°C	108.30	86.04	72.74	63.95	57.50	52.82
Approach (5)°C	135.56	107.17	90.07	78.70	70.56	64.59
Approach (6)°C	164.18	129.19	108.22	94.35	84.43	77.01
Approach (7)°C	194.26	152.41	127.41	110.72	98.86	89.99
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	87.01	69.75	59.35	52.58	47.74	43.95
Approach (4)°C	114.19	90.88	76.85	67.50	60.88	55.96
Approach (5)°C	142.65	112.98	95.07	83.14	74.75	68.38
Approach (6)°C	172.81	136.12	114.19	99.59	89.19	81.45
Approach (7)°C	204.42	160.47	134.35	116.85	104.51	95.16
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	91.69	73.54	62.82	55.56	50.48	46.61
Approach (4)°C	120.31	95.96	81.29	71.53	62.82	59.19
Approach (5)°C	150.31	119.02	100.40	87.98	79.03	72.33
Approach (6)°C	181.76	143.46	120.48	105.24	94.27	86.04
Approach (7)°C	214.91	169.18	141.60	123.38	110.32	100.72
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	96.69	77.90	66.53	59.03	53.54	49.35
Approach (4)°C	126.77	101.28	85.80	75.72	68.22	62.74
Approach (5)°C	158.30	125.72	105.96	92.98	83.54	76.61
Approach (6)°C	191.44	151.28	127.17	111.20	99.75	91.12
Approach (7)°C	226.11	178.21	149.51	130.31	116.69	106.44
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	102.01	82.25	70.48	62.42	56.77	52.34
Approach (4)°C	133.70	106.93	90.72	79.99	72.17	66.45
Approach (5)°C	166.84	132.57	112.09	98.30	88.46	81.12
Approach (6)°C	201.60	159.51	134.27	117.57	105.48	96.53
Approach (7)°C	238.21	187.81	157.81	137.73	123.38	112.57
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	107.90	87.33	74.59	66.12	60.24	55.64
Approach (4)°C	141.12	113.14	96.04	84.67	76.77	70.48
Approach (5)°C	175.88	139.99	118.54	104.11	93.70	85.96
Approach (6)°C	212.41	168.30	141.85	124.27	111.61	102.17
Approach (7)°C	250.63	198.05	166.60	145.56	130.48	119.19

HKB1521

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	114.19	92.17	79.03	70.16	63.79	58.95
Approach (4)°C	149.02	119.43	101.69	89.75	81.20	74.83
Approach (5)°C	185.39	147.97	125.23	110.15	99.35	91.12
Approach (6)°C	223.78	177.65	150.07	131.52	118.22	108.30
Approach (7)°C	264.10	209.02	176.04	153.86	138.06	126.28
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	120.23	97.66	83.78	74.59	67.82	62.66
Approach (4)°C	157.33	126.28	107.57	95.07	86.12	79.35
Approach (5)°C	195.63	156.20	132.49	116.61	105.24	96.61
Approach (6)°C	235.87	187.57	158.46	139.02	125.23	114.75
Approach (7)°C	278.21	220.47	185.88	162.65	146.12	133.78
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	127.33	103.30	88.87	79.11	71.93	66.61
Approach (4)°C	166.04	133.70	113.86	100.80	91.28	84.27
Approach (5)°C	206.36	164.99	140.15	123.46	111.53	102.49
Approach (6)°C	248.86	198.13	167.65	147.17	132.57	121.69
Approach (7)°C	293.13	232.73	196.44	172.09	154.75	141.68
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	134.67	109.51	94.11	83.87	76.45	70.80
Approach (4)°C	175.39	141.28	120.72	106.93	96.93	89.43
Approach (5)°C	217.81	174.42	148.30	130.80	118.22	108.86
Approach (6)°C	262.40	209.18	177.17	155.88	140.56	129.02
Approach (7)°C	309.01	245.71	207.57	182.17	163.94	150.23
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	142.41	115.96	99.83	89.03	81.20	75.32
Approach (4)°C	185.39	149.51	127.90	113.30	102.82	94.99
Approach (5)°C	229.99	184.42	156.93	138.54	125.40	115.56
Approach (6)°C	276.76	221.11	187.41	165.07	148.94	136.85
Approach (7)°C	325.95	259.50	219.50	192.81	173.70	159.18
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	150.72	122.81	105.96	94.59	86.28	80.08
Approach (4)°C	195.79	158.22	135.56	120.15	109.27	100.96
Approach (5)°C	242.81	194.99	166.20	146.85	132.98	122.57
Approach (6)°C	292.08	233.53	198.29	174.83	157.89	145.15
Approach (7)°C	343.61	273.93	232.00	204.02	183.94	168.86

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	106.35	86.11	73.75	65.48	59.50	54.93
Approach (4)°C	138.66	111.20	94.66	83.54	75.56	69.47
Approach (5)°C	172.12	137.43	116.33	102.26	92.19	84.59
Approach (6)°C	207.28	164.61	138.95	121.84	109.49	100.27
Approach (7)°C	243.97	193.22	162.61	142.37	127.73	116.71
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	112.15	90.76	77.93	69.28	62.92	58.16
Approach (4)°C	145.98	117.18	99.89	88.20	79.83	73.56
Approach (5)°C	181.15	144.56	122.70	107.97	97.32	89.53
Approach (6)°C	217.93	173.26	146.46	128.49	115.66	105.97
Approach (7)°C	256.23	203.20	171.36	149.97	134.77	123.27
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	118.13	95.80	82.30	73.18	66.62	61.68
Approach (4)°C	153.58	123.65	105.40	93.23	84.49	77.84
Approach (5)°C	190.56	152.44	129.44	113.95	102.93	94.56
Approach (6)°C	229.05	182.48	154.44	135.62	122.22	112.05
Approach (7)°C	269.15	213.84	180.58	158.24	142.27	130.30
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	124.60	101.22	87.06	77.46	70.52	65.39
Approach (4)°C	161.76	130.39	111.29	98.56	89.34	82.40
Approach (5)°C	200.63	160.62	136.48	120.42	108.82	100.08
Approach (6)°C	240.93	192.17	162.80	143.13	129.16	118.42
Approach (7)°C	282.93	225.05	190.18	166.89	150.26	137.71
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	131.35	107.02	92.09	82.11	74.80	69.28
Approach (4)°C	170.41	137.52	117.66	104.26	94.56	87.34
Approach (5)°C	210.99	169.36	144.18	127.16	115.00	106.06
Approach (6)°C	253.38	202.44	171.83	151.21	136.48	125.36
Approach (7)°C	297.57	237.12	200.63	176.30	158.72	145.51
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	138.66	113.00	97.42	86.87	79.26	73.47
Approach (4)°C	179.63	145.13	124.31	110.25	100.17	92.47
Approach (5)°C	222.20	178.58	152.25	134.48	121.84	112.15
Approach (6)°C	266.59	213.36	181.24	159.67	144.27	132.68
Approach (7)°C	312.97	249.77	211.56	186.09	167.65	153.96

HKB2026

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	146.36	119.47	103.12	92.00	84.02	78.03
Approach (4)°C	189.41	153.30	131.44	116.71	106.06	98.08
Approach (5)°C	233.99	188.37	160.81	142.18	128.87	118.80
Approach (6)°C	280.65	224.96	191.32	168.70	152.54	140.37
Approach (7)°C	329.22	262.98	223.15	196.45	177.25	162.80
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	154.54	126.31	109.20	97.51	89.15	82.78
Approach (4)°C	199.68	161.95	139.04	123.65	112.43	103.97
Approach (5)°C	246.53	198.82	169.84	150.35	136.38	125.83
Approach (6)°C	295.29	237.22	201.96	178.30	161.28	148.64
Approach (7)°C	346.52	277.23	235.51	207.47	187.32	172.31
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	163.09	133.63	115.57	103.40	94.56	87.91
Approach (4)°C	210.61	171.07	147.03	130.78	119.09	110.34
Approach (5)°C	259.84	209.85	179.53	159.10	144.46	133.34
Approach (6)°C	311.16	250.05	213.27	188.65	170.79	157.48
Approach (7)°C	364.67	292.25	248.53	219.26	198.25	182.48
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	172.40	141.42	122.51	109.68	100.36	93.33
Approach (4)°C	222.20	180.67	155.58	138.57	126.31	116.99
Approach (5)°C	273.81	221.44	189.98	168.41	153.11	141.42
Approach (6)°C	327.79	263.93	225.34	199.30	180.77	166.70
Approach (7)°C	383.96	308.12	262.31	231.80	209.66	193.12
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	182.10	149.59	129.82	116.33	106.63	99.13
Approach (4)°C	234.46	191.03	164.61	146.74	133.91	124.12
Approach (5)°C	288.83	233.99	200.63	178.20	162.14	149.88
Approach (6)°C	345.19	278.56	238.08	210.89	191.32	176.49
Approach (7)°C	404.40	324.94	277.14	244.82	221.82	204.53
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	192.55	158.34	137.62	123.36	113.19	105.30
Approach (4)°C	247.58	202.06	174.21	155.58	141.99	131.82
Approach (5)°C	304.60	247.01	212.22	188.65	171.74	158.91
Approach (6)°C	364.00	293.96	251.57	223.06	202.63	187.23
Approach (7)°C	426.06	342.81	292.63	258.98	234.84	216.60

HKB3031

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	122.88	99.69	85.55	76.16	69.32	64.22
Approach (4)°C	159.97	128.32	109.31	96.68	87.52	80.68
Approach (5)°C	198.69	158.23	134.12	117.89	106.41	97.72
Approach (6)°C	239.37	189.76	160.09	140.26	126.12	115.57
Approach (7)°C	282.15	222.68	187.21	163.56	146.75	134.12
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	129.37	105.02	90.30	80.33	73.26	67.93
Approach (4)°C	168.32	135.16	115.22	101.89	92.39	85.20
Approach (5)°C	208.89	166.69	141.19	124.38	112.21	103.17
Approach (6)°C	251.55	199.73	168.55	147.80	132.96	121.95
Approach (7)°C	296.18	234.16	197.06	172.37	154.75	141.54
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	136.21	110.70	95.29	84.85	77.43	71.75
Approach (4)°C	177.01	142.35	121.48	107.57	97.60	89.95
Approach (5)°C	219.67	175.39	148.84	131.11	118.47	108.96
Approach (6)°C	264.30	210.05	177.47	155.80	140.26	128.67
Approach (7)°C	311.25	246.45	207.61	181.65	163.22	149.42
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	143.51	116.73	100.50	89.61	81.84	75.81
Approach (4)°C	186.28	150.00	128.21	113.49	103.05	95.17
Approach (5)°C	231.03	184.78	156.96	138.41	125.08	115.11
Approach (6)°C	277.98	221.18	187.09	164.37	148.15	135.97
Approach (7)°C	327.24	259.43	218.63	191.62	172.26	157.77
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	151.28	123.22	106.18	94.71	86.48	80.33
Approach (4)°C	196.25	158.11	135.28	119.98	108.96	100.62
Approach (5)°C	243.20	194.75	165.53	146.06	132.15	121.72
Approach (6)°C	292.47	232.88	197.30	173.42	156.38	143.62
Approach (7)°C	344.05	273.11	230.45	202.16	181.76	166.69
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	159.39	130.06	112.21	100.15	91.58	84.97
Approach (4)°C	206.69	166.81	142.81	126.70	115.11	106.41
Approach (5)°C	255.95	205.29	174.69	154.29	139.57	128.67
Approach (6)°C	307.77	245.40	208.08	183.04	165.19	151.86
Approach (7)°C	362.02	287.60	242.97	213.18	191.96	176.08

HKB3031

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	168.20	137.37	118.59	105.95	96.91	90.07
Approach (4)°C	217.81	175.97	150.81	133.89	121.83	112.67
Approach (5)°C	269.63	216.42	184.43	162.98	147.57	136.09
Approach (6)°C	324.00	258.62	219.44	193.24	174.58	160.55
Approach (7)°C	380.91	303.01	256.18	225.12	202.86	186.05
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	177.47	145.02	125.31	112.09	102.59	95.29
Approach (4)°C	229.64	185.82	159.27	141.54	128.79	119.28
Approach (5)°C	284.12	228.25	194.63	172.26	156.14	143.97
Approach (6)°C	341.15	272.76	231.61	204.14	184.54	169.82
Approach (7)°C	400.97	319.24	270.33	237.64	214.34	196.83
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	187.33	153.25	132.61	118.70	108.62	101.08
Approach (4)°C	242.16	196.14	168.43	149.77	136.44	126.24
Approach (5)°C	299.31	240.77	205.64	181.99	165.07	152.43
Approach (6)°C	359.35	287.60	244.48	215.73	195.09	179.56
Approach (7)°C	422.18	336.63	285.28	251.08	226.51	208.08
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	197.76	162.06	140.38	125.66	115.11	107.11
Approach (4)°C	255.37	207.15	177.94	158.46	144.44	133.77
Approach (5)°C	315.65	254.21	217.23	192.43	174.69	161.36
Approach (6)°C	378.59	303.36	258.15	228.01	206.34	190.11
Approach (7)°C	444.67	355.06	301.16	265.22	239.49	220.13
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	208.89	171.33	148.49	133.19	121.95	113.60
Approach (4)°C	269.40	218.86	188.25	167.74	152.90	141.77
Approach (5)°C	332.69	268.35	229.52	203.56	184.89	170.87
Approach (6)°C	399.00	320.06	272.76	241.00	218.28	201.24
Approach (7)°C	468.43	374.42	317.97	280.18	253.29	233.00
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	220.71	181.18	157.19	140.96	129.37	120.44
Approach (4)°C	284.35	231.26	199.15	177.47	162.06	150.23
Approach (5)°C	350.89	283.42	242.62	215.38	195.79	181.07
Approach (6)°C	420.56	337.91	288.18	254.91	231.03	213.06
Approach (7)°C	493.70	394.94	335.82	296.18	267.89	246.68

HKB4036

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	148.65	122.73	106.92	96.55	88.78	82.81
Approach (4)°C	189.73	154.87	133.62	119.75	109.51	101.87
Approach (5)°C	232.89	187.79	160.96	143.47	130.64	120.79
Approach (6)°C	276.57	222.26	189.86	167.83	152.67	141.00
Approach (7)°C	322.06	258.55	219.80	193.75	175.74	162.00
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	155.52	129.34	112.36	101.22	93.31	87.35
Approach (4)°C	199.07	162.00	139.97	125.58	115.08	107.05
Approach (5)°C	243.65	196.99	169.52	150.85	137.25	127.40
Approach (6)°C	290.30	233.28	199.45	176.52	160.57	148.13
Approach (7)°C	338.90	271.51	231.21	203.99	184.94	170.16
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	163.56	135.30	118.20	106.66	98.24	91.63
Approach (4)°C	208.14	170.55	147.61	132.19	121.05	112.62
Approach (5)°C	255.31	206.97	178.07	158.50	144.50	134.01
Approach (6)°C	304.30	244.94	209.56	185.72	168.87	156.04
Approach (7)°C	355.36	284.73	242.61	214.23	194.14	179.11
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	171.72	142.17	124.29	112.10	103.42	96.68
Approach (4)°C	218.89	179.11	155.13	138.93	127.40	118.58
Approach (5)°C	267.88	217.34	186.88	166.54	152.02	141.00
Approach (6)°C	319.20	257.13	220.06	195.31	177.55	164.20
Approach (7)°C	372.73	298.99	254.66	225.24	204.12	188.44
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	180.40	149.56	130.64	117.94	108.86	101.87
Approach (4)°C	229.78	188.18	163.04	146.19	134.01	124.93
Approach (5)°C	281.23	228.36	196.47	175.22	159.93	148.52
Approach (6)°C	335.02	270.09	231.21	205.42	186.75	172.76
Approach (7)°C	391.13	314.02	267.62	236.91	214.88	198.29
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	189.60	157.33	137.51	124.29	114.70	107.31
Approach (4)°C	241.32	197.90	171.46	153.84	141.13	131.54
Approach (5)°C	295.36	240.02	206.71	184.42	168.48	156.30
Approach (6)°C	351.73	283.95	243.26	216.17	196.60	182.09
Approach (7)°C	410.83	330.09	281.49	249.22	226.15	208.79

HKB4036

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	199.32	165.37	144.76	130.77	120.79	113.14
Approach (4)°C	253.63	208.14	180.53	162.00	148.65	138.54
Approach (5)°C	310.26	252.33	217.47	194.14	177.29	164.72
Approach (6)°C	369.49	298.60	255.96	227.45	207.10	191.81
Approach (7)°C	431.57	358.60	296.01	262.31	238.08	219.93
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	209.56	174.05	152.41	137.89	127.27	119.23
Approach (4)°C	266.59	218.89	189.99	170.68	156.69	146.06
Approach (5)°C	326.07	265.42	228.87	204.38	186.75	173.66
Approach (6)°C	388.28	313.76	269.31	239.50	217.99	202.05
Approach (7)°C	453.34	364.69	311.56	276.05	250.78	231.85
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	220.58	183.25	160.70	145.28	134.14	125.84
Approach (4)°C	280.45	230.30	200.10	179.76	165.11	154.09
Approach (5)°C	342.79	279.29	240.93	215.27	196.86	183.12
Approach (6)°C	408.24	330.22	283.44	252.33	229.78	213.06
Approach (7)°C	476.41	383.62	327.89	290.69	264.12	244.30
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	231.98	193.10	169.26	153.19	141.52	132.71
Approach (4)°C	294.97	242.61	210.86	189.48	174.18	162.65
Approach (5)°C	360.42	293.93	253.76	226.93	207.62	192.97
Approach (6)°C	429.11	347.46	298.47	265.81	242.22	224.60
Approach (7)°C	501.03	403.57	345.25	306.24	278.51	257.64
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	244.30	203.47	178.46	161.74	149.43	140.23
Approach (4)°C	310.52	255.44	222.13	199.84	183.77	171.59
Approach (5)°C	379.47	309.48	267.36	239.11	218.89	203.73
Approach (6)°C	451.40	365.73	314.41	280.07	255.44	237.04
Approach (7)°C	527.08	424.83	363.66	322.83	293.67	271.77
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	257.26	214.36	188.18	170.55	157.72	148.13
Approach (4)°C	326.85	269.05	234.19	210.73	193.88	181.18
Approach (5)°C	399.17	325.94	281.88	252.20	230.95	215.01
Approach (6)°C	474.85	385.17	331.26	295.36	269.57	250.13
Approach (7)°C	554.43	447.25	383.10	340.20	309.74	286.80

HKB6046

Wet Bulb Temp. (18)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	210.65	171.06	146.53	129.95	117.93	108.96
Approach (4)°C	272.92	220.47	188.32	166.32	150.59	138.57
Approach (5)°C	337.22	271.40	230.96	203.72	184.09	169.20
Approach (6)°C	403.20	323.51	275.12	242.29	218.44	200.50
Approach (7)°C	471.73	377.65	320.63	282.06	254.14	233.33
Wet Bulb Temp. (19)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	221.99	180.54	155.16	137.73	125.21	115.73
Approach (4)°C	287.30	232.48	198.81	176.14	159.56	146.87
Approach (5)°C	354.30	285.78	243.65	215.22	194.58	179.18
Approach (6)°C	423.51	340.43	289.84	255.66	230.96	212.18
Approach (7)°C	495.25	396.94	337.55	297.45	268.52	246.52
Wet Bulb Temp. (20)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	234.00	190.86	164.12	146.02	132.99	122.84
Approach (4)°C	302.36	245.34	210.15	186.29	169.03	155.83
Approach (5)°C	372.41	300.84	257.18	227.57	205.92	189.50
Approach (6)°C	444.66	358.20	305.41	270.04	243.99	224.53
Approach (7)°C	519.61	417.59	355.49	313.87	283.58	260.57
Wet Bulb Temp. (21)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	246.86	201.69	173.77	154.82	141.11	130.62
Approach (4)°C	318.27	258.71	222.16	197.12	179.18	165.31
Approach (5)°C	391.36	316.91	271.40	240.60	217.93	201.01
Approach (6)°C	467.16	376.98	321.99	284.93	258.03	237.56
Approach (7)°C	545.84	439.24	374.61	330.79	299.48	275.63
Wet Bulb Temp. (22)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	260.40	213.36	184.09	164.29	149.74	138.91
Approach (4)°C	335.19	272.92	234.85	208.79	189.84	175.63
Approach (5)°C	411.83	334.00	286.46	254.14	230.79	212.85
Approach (6)°C	491.02	397.11	339.58	301.01	272.75	251.60
Approach (7)°C	573.08	461.92	394.57	349.06	316.23	291.36
Wet Bulb Temp. (23)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	274.78	225.54	195.09	174.28	159.22	147.54
Approach (4)°C	353.12	288.15	248.22	221.14	201.18	186.29
Approach (5)°C	433.32	352.11	302.36	268.86	244.32	225.71
Approach (6)°C	516.23	418.09	358.20	317.93	288.32	266.49
Approach (7)°C	601.84	486.11	415.89	368.35	334.17	308.11

HKB6046

Wet Bulb Temp. (24)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	290.01	238.40	206.76	185.10	169.20	157.02
Approach (4)°C	372.07	304.05	262.60	234.00	213.53	197.79
Approach (5)°C	455.99	371.22	319.62	284.26	258.54	239.42
Approach (6)°C	542.79	440.26	377.99	335.86	305.07	281.89
Approach (7)°C	632.81	511.83	438.40	388.82	353.12	326.05
Wet Bulb Temp. (25)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	306.25	252.45	219.11	196.27	179.69	167.00
Approach (4)°C	392.04	321.31	277.66	247.88	226.39	209.98
Approach (5)°C	479.85	391.53	337.38	300.67	273.93	253.80
Approach (6)°C	570.71	463.95	398.64	354.81	322.83	298.64
Approach (7)°C	664.96	538.39	461.92	410.48	373.42	345.00
Wet Bulb Temp. (26)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	323.34	267.00	232.31	208.29	191.03	177.83
Approach (4)°C	413.19	339.42	293.90	262.77	240.26	223.01
Approach (5)°C	505.06	413.02	356.50	318.27	290.18	269.03
Approach (6)°C	600.15	488.65	420.80	374.95	341.61	316.23
Approach (7)°C	699.13	567.16	487.13	433.49	394.57	365.13
Wet Bulb Temp. (27)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	341.28	282.73	246.36	221.31	203.21	189.17
Approach (4)°C	435.52	358.53	310.82	278.33	254.98	236.88
Approach (5)°C	531.96	435.35	376.64	336.54	307.44	285.44
Approach (6)°C	631.62	514.88	444.15	396.27	361.41	335.02
Approach (7)°C	735.00	597.28	513.86	457.69	417.25	386.45
Wet Bulb Temp. (28)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	360.40	298.98	261.08	234.85	215.90	201.35
Approach (4)°C	459.21	378.67	328.92	295.08	270.38	251.60
Approach (5)°C	560.22	459.72	398.13	356.17	325.88	302.70
Approach (6)°C	664.62	543.13	468.85	418.60	382.56	354.98
Approach (7)°C	773.24	628.92	541.95	483.40	441.27	408.96
Wet Bulb Temp. (29)°C (m ³ /hr)						
	Range (3)°C	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	380.70	316.74	276.64	249.40	229.60	214.21
Approach (4)°C	484.25	400.16	348.21	312.85	286.96	267.34
Approach (5)°C	590.00	484.93	420.63	376.98	345.34	321.14
Approach (6)°C	699.47	572.23	494.91	442.63	404.90	376.13
Approach (7)°C	813.34	662.76	571.90	510.65	466.48	432.98