

KC80					
Wet Bulb Temp. (21)°C			Water flow (m3/hr)		
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	32.2293	25.6149	24.5496	21.7724	19.7213
Approach (4)°C	42.4106	34.7468	32.012	28.6518	26.1078
Approach (5)°C	52.5919	43.8787	39.4744	35.5312	32.4943
Approach (6)°C	62.7732	53.0106	46.9368	42.4106	38.8808
Wet Bulb Temp. (22)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	33.0137	27.3480	26.4311	23.2511	20.8449
Approach (4)°C	44.0006	37.2537	34.1055	30.4114	27.5123
Approach (5)°C	54.9875	47.1594	41.7799	37.5717	34.1797
Approach (6)°C	65.9744	57.0651	49.4543	44.7320	40.8471
Wet Bulb Temp. (23)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	37.3120	32.3088	27.7031	25.3128	22.5992
Approach (4)°C	47.8007	41.1439	35.7962	32.6215	29.4786
Approach (5)°C	58.2894	49.9790	43.8893	39.9302	36.3580
Approach (6)°C	68.7781	58.8141	51.9824	47.2389	43.2374
Wet Bulb Temp. (24)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	36.8668	32.1816	30.3743	27.2897	24.7086
Approach (4)°C	49.5338	42.7127	38.4674	34.8051	31.7258
Approach (5)°C	62.2008	53.2438	46.5605	42.3205	38.743
Approach (6)°C	73.1100	63.7749	54.6536	49.8359	45.7602
Wet Bulb Temp. (25)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	41.6527	35.9764	31.747	28.5458	26.4788
Approach (4)°C	52.8092	45.6065	40.2906	36.517	33.7398
Approach (5)°C	63.9657	55.2366	48.8342	44.4882	41.0008
Approach (6)°C	76.845	64.8667	57.3778	52.4594	48.2618
Wet Bulb Temp. (26)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	44.0430	37.8738	33.7080	30.7347	28.4610
Approach (4)°C	55.8196	47.8749	42.6173	38.8861	35.9234
Approach (5)°C	67.5962	57.8760	51.5266	47.0375	43.3858
Approach (6)°C	79.3728	67.8771	60.4359	55.1889	50.8482
Wet Bulb Temp. (27)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	46.4068	40.1263	35.8651	32.8070	30.0722
Approach (4)°C	58.3159	50.6203	45.0818	41.2181	37.9215
Approach (5)°C	70.2250	61.1143	54.2985	49.6292	45.7708
Approach (6)°C	82.1341	71.6083	63.5152	58.0403	53.6201
Wet Bulb Temp. (28)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	48.8607	42.2622	37.8420	34.6302	32.2664
Approach (4)°C	61.7874	53.0795	47.4774	43.4653	40.3595
Approach (5)°C	74.7141	63.8968	57.1128	52.3004	48.4526
Approach (6)°C	87.6408	74.7141	66.7482	61.1355	56.5457

KC80		Wet Bulb Temp. (29)°C			Water flow (m3/hr)	
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	51.5001	44.8857	40.0150	36.9145	34.2963	
Approach (4)°C	64.4268	56.1641	50.1115	46.0517	42.7074	
Approach (5)°C	77.3535	67.4425	60.2080	55.1889	51.1185	
Approach (6)°C	90.2802	78.7209	70.3045	64.3261	59.5296	

KC100		Wet Bulb Temp. (21)°C			Water flow (m3/hr)	
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	40.7427	32.3811	31.0344	27.5236	24.9307	
Approach (4)°C	53.6134	43.9252	40.468	36.2202	33.0042	
Approach (5)°C	66.4841	55.4693	49.9016	44.9168	41.0777	
Approach (6)°C	79.3548	67.0134	59.3352	53.6134	49.1512	
Wet Bulb Temp. (22)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	41.7343	34.5720	33.4129	29.3929	26.3511	
Approach (4)°C	55.6234	47.0943	43.1145	38.4446	34.7797	
Approach (5)°C	69.5125	59.6166	52.8161	47.4963	43.2083	
Approach (6)°C	83.4016	72.1389	62.5177	56.5480	51.6369	
Wet Bulb Temp. (23)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	47.1680	40.8432	35.0209	31.9992	28.5688	
Approach (4)°C	60.4273	52.0121	45.2518	41.2385	37.2654	
Approach (5)°C	73.6866	63.1810	55.4827	50.4778	45.9620	
Approach (6)°C	86.9459	74.3499	65.7136	59.7171	54.6586	
Wet Bulb Temp. (24)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	46.6052	40.6824	38.3977	34.4983	31.2354	
Approach (4)°C	62.6182	53.9953	48.6286	43.9989	40.1062	
Approach (5)°C	78.6312	67.3082	58.8595	53.4995	48.977	
Approach (6)°C	92.4220755	80.6211	69.0904	63.0001	57.8478	
Wet Bulb Temp. (25)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	52.6553	45.4796	40.1330	36.0862	33.4732	
Approach (4)°C	66.7588	57.6535	50.9334	46.1630	42.6522	
Approach (5)°C	80.8623	69.8274	61.7338	56.2398	51.8312	
Approach (6)°C	97.1437	82.0013	72.5342	66.3166	61.0102	
Wet Bulb Temp. (26)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	55.6770	47.8782	42.6120	38.8533	35.9790	
Approach (4)°C	70.5644	60.5211	53.8747	49.1579	45.4126	
Approach (5)°C	85.4518	73.1640	65.1374	59.4625	54.8462	
Approach (6)°C	100.3392	85.8069	76.4001	69.7671	64.2798	
Wet Bulb Temp. (27)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	58.6652	50.7257	45.3389	41.4730	38.0158	
Approach (4)°C	73.7201	63.9917	56.9902	52.1059	47.9385	
Approach (5)°C	88.7750	77.2577	68.6415	62.7388	57.8612	
Approach (6)°C	103.8299	90.5237	80.2928	73.3717	67.7839	
Wet Bulb Temp. (28)°C						
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C	
Approach (3)°C	61.7673	53.4258	47.8380	43.7778	40.7896	
Approach (4)°C	78.1086	67.1005	60.0186	54.9467	51.0205	
Approach (5)°C	94.4499	80.7752	72.1992	66.1156	61.2514	
Approach (6)°C	110.7912	94.4499	84.3798	77.2845	71.4823	

KC100	Wet Bulb Temp. (29)°C			Water flow (m3/hr)	
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	65.1039	56.7423	50.5850	46.6655	43.3557
Approach (4)°C	81.4452	70.9999	63.3485	58.2163	53.9886
Approach (5)°C	97.7865	85.2575	76.1120	69.7671	64.6215
Approach (6)°C	114.1278	99.5151	88.8755	81.3179	75.2544

KC125					
Wet Bulb Temp. (21)°C			Water flow (m3/hr)		
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	51.0804	40.5972	38.9088	34.5072	31.2564
Approach (4)°C	67.2168	55.0704	50.736	45.4104	41.3784
Approach (5)°C	83.3532	69.5436	62.5632	56.3136	51.5004
Approach (6)°C	99.4896	84.0168	74.3904	67.2168	61.6224
Wet Bulb Temp. (22)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	52.3236	43.344	41.8908	36.8508	33.0372
Approach (4)°C	69.7368	59.0436	54.054	48.1992	43.6044
Approach (5)°C	87.15	74.7432	66.2172	59.5476	54.1716
Approach (6)°C	104.5632	90.4428	78.3804	70.896	64.7388
Wet Bulb Temp. (23)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	59.136	51.2064	43.9068	40.1184	35.8176
Approach (4)°C	75.7596	65.2092	56.7336	51.702	46.7208
Approach (5)°C	92.3832	79.212	69.5604	63.2856	57.624
Approach (6)°C	109.0068	93.2148	82.3872	74.8692	68.5272
Wet Bulb Temp. (24)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	58.4304	51.0048	48.1404	43.2516	39.1608
Approach (4)°C	78.5064	67.6956	60.9672	55.1628	50.2824
Approach (5)°C	98.5824	84.3864	73.794	67.074	61.404
Approach (6)°C	115.872453	101.0772	86.6208	78.9852	72.5256
Wet Bulb Temp. (25)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	66.0156	57.0192	50.316	45.2424	41.9664
Approach (4)°C	83.6976	72.282	63.8568	57.876	53.4744
Approach (5)°C	101.3796	87.5448	77.3976	70.5096	64.9824
Approach (6)°C	121.792075	102.8076	90.9384	83.1432	76.4904
Wet Bulb Temp. (26)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	69.804	60.0264	53.424	48.7116	45.108
Approach (4)°C	88.4688	75.8772	67.5444	61.6308	56.9352
Approach (5)°C	107.1336	91.728	81.6648	74.55	68.7624
Approach (6)°C	125.7984	107.5788	95.7852	87.4692	80.5896
Wet Bulb Temp. (27)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	73.5504	63.5964	56.8428	51.996	47.6616
Approach (4)°C	92.4252	80.2284	71.4504	65.3268	60.102
Approach (5)°C	111.300	96.8604	86.058	78.6576	72.5424
Approach (6)°C	130.1748	113.4924	100.6656	91.9884	84.9828
Wet Bulb Temp. (28)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	77.4396	66.9816	59.976	54.8856	51.1392
Approach (4)°C	97.9272	84.126	75.2472	68.8884	63.966
Approach (5)°C	118.4148	101.2704	90.5184	82.8912	76.7928
Approach (6)°C	138.9024	118.4148	105.7896	96.894	89.6196

KC125	Wet Bulb Temp. (29)°C			Water flow (m3/hr)	
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	81.6228	71.1396	63.42	58.506	54.3564
Approach (4)°C	102.1104	89.0148	79.422	72.9876	67.6872
Approach (5)°C	122.598	106.89	95.424	87.4692	81.018
Approach (6)°C	143.0856	124.7652	111.426	101.9508	94.3488

KC150					
Wet Bulb Temp. (21)°C			Water flow (m3/hr)		
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	62.0262	49.2966	47.2464	41.9016	37.9542
Approach (4)°C	81.6204	66.8712	61.608	55.1412	50.2452
Approach (5)°C	101.2146	84.4458	75.9696	68.3808	62.5362
Approach (6)°C	120.8088	102.0204	90.3312	81.6204	74.8272
Wet Bulb Temp. (22)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	63.5358	52.632	50.8674	44.7474	40.1166
Approach (4)°C	84.6804	71.6958	65.637	58.5276	52.9482
Approach (5)°C	105.825	90.7596	80.4066	72.3078	65.7798
Approach (6)°C	126.9696	109.8234	95.1762	86.088	78.6114
Wet Bulb Temp. (23)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	71.808	62.1792	53.3154	48.7152	43.4928
Approach (4)°C	91.9938	79.1826	68.8908	62.781	56.7324
Approach (5)°C	112.1796	96.186	84.4662	76.8468	69.972
Approach (6)°C	132.3654	113.1894	100.0416	90.9126	83.2116
Wet Bulb Temp. (24)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	70.9512	61.9344	58.4562	52.5198	47.5524
Approach (4)°C	95.3292	82.2018	74.0316	66.9834	61.0572
Approach (5)°C	119.7072	102.4692	89.607	81.447	74.562
Approach (6)°C	140.702264	122.7366	105.1824	95.9106	88.0668
Wet Bulb Temp. (25)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	80.1618	69.2376	61.098	54.9372	50.9592
Approach (4)°C	101.6328	87.771	77.5404	70.278	64.9332
Approach (5)°C	123.1038	106.3044	93.9828	85.6188	78.9072
Approach (6)°C	147.890377	124.8378	110.4252	100.9596	92.8812
Wet Bulb Temp. (26)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	84.762	72.8892	64.872	59.1498	54.774
Approach (4)°C	107.4264	92.1366	82.0182	74.8374	69.1356
Approach (5)°C	130.0908	111.384	99.1644	90.525	83.4972
Approach (6)°C	152.7552	130.6314	116.3106	106.2126	97.8588
Wet Bulb Temp. (27)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	89.3112	77.2242	69.0234	63.138	57.8748
Approach (4)°C	112.2306	97.4202	86.7612	79.3254	72.981
Approach (5)°C	135.15	117.6162	104.499	95.5128	88.0872
Approach (6)°C	158.0694	137.8122	122.2368	111.7002	103.1934
Wet Bulb Temp. (28)°C					
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	94.0338	81.3348	72.828	66.6468	62.0976
Approach (4)°C	118.9116	102.153	91.3716	83.6502	77.673
Approach (5)°C	143.7894	122.9712	109.9152	100.6536	93.2484
Approach (6)°C	168.6672	143.7894	128.4588	117.657	108.8238

KC150	Wet Bulb Temp. (29)°C			Water flow (m3/hr)	
	Range (4)°C	Range (5)°C	Range (6)°C	Range (7)°C	Range (8)°C
Approach (3)°C	99.1134	86.3838	77.01	71.043	66.0042
Approach (4)°C	123.9912	108.0894	96.441	88.6278	82.1916
Approach (5)°C	148.869	129.795	115.872	106.2126	98.379
Approach (6)°C	173.7468	151.5006	135.303	123.7974	114.5664